

FLANGED BALL VALVE

Client: J.C. FABRICA DE VALVULAS, S.A.

Certificate Number: BCL 9800596/1

Office BARCELONA

Client's Order Number.

Date 15.06.98

Order Status complete

Inspection Dates

First: 15.05.98

Final: 15.05.98

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 2" full bore, bi-directional as per

Fig. 2515 A.I.T. DN 2", ANSI 150# RF,FB

Body material: A-216- WCB

Seats: PTFE

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: 2.515.501

Body connector: 2.515.502

Mass: 13 Kgs Marks:

BODY : BODY CONNECTOR :

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593° C minimum and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.

C253

C253

../... A

NOTICE: This certificate is subject to the terms and conditions overleaf, which form part of this certificate.

FORM 1123 (05/96)

Lloyd's Register of Shipping, registered office: 71 Fenchurch Street, London EC3M 4BS



Certificate Number: BCL 9800596/1

Office: BARCELONA
Date: 15.06.98
Page: 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2515/2"

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.

The manufacturers Fire Safe Test Report no. API 607-2515/2" and drawing 1303/2515NAIT50-M1 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

h 1	т	\sim
	ш	^

CLASS RATING

MATERIALS


11/2, 2, 21/2, 3

150# and 300#

Carbon steel, (see drawing)

J.Gil for P. Picazo
Surveyors to Lloyd's Register

DOCUMENTS ATTACHED:





FIRE TEST FOR SOFT-SEATED Project:

FLANGED BALL VALVE

Certificate Number.

BCL 9800596/2

J.C. FABRICA DE VALVULAS, S.A.

BARCELONA

Client's Order Number.

15.06.98 Date:

Order Status

complete

Inspection Dates

15.05.98 First:

15.05.98

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 4" full bore, bi-directional as per

Fig. 2515 A.I.T. DN 4", ANSI 150# RF,FB

Body material: A-216- WCB

Seats: PTFE

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: 25151001

Body connector: 25151002

Mass: 49 Kgs

Marks:

BODY

801

BODY CONNECTOR

790

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593° C minimum and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.





Certificate Number: BCL 9800596/2

Office: BARCELONA

Date: 15.06.98 Page: 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2515/4"

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.


The manufacturers Fire Safe Test Report no. API 607-2515/4" and drawing 2270/2515HAIT100SI herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

<u>NPS</u>	CLASS RATING	MATERIALS
3,4,5,6	150# and 300#	Carbon steel, (see drawing)

J.Gil for P. Picazo Surveyors to Lloyd's Register

DOCUMENTS ATTACHED:





FLANGED BALL VALVE

Certificate Number: BCL 9800603/2A1

Client: J.C. FABRICA DE VALVULAS, S.A.

Office: BARCELONA

Client's Order Number. ---

Date: 30.06.98

Order Status: complete

Inspection Dates

First: 26.05.98

Final: 26.05.98

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 8" full bore, bi-directional as per

Fig. 2515 A.I.T. DN 8", ANSI 150# RF,FB

Body material: A-216- WCB

Seats: PTFE

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: 25152001

Body connector: 25152002

Mass: 184 Kgs

Marks:

BODY

D-08

BODY CONNECTOR

N-02

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593° C minimun and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.



Certificate Number: BCL 9800603/2A1 Office BARCELONA Date: 30.06.98 Page 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2515/8"

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.

The manufacturers Fire Safe Test Report no. API 607-2515/8" and drawing 2334/2515HAIT200RA herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

> **NPS CLASS RATING** MATERIALS

6" and larger 150# and 300# Carbon steel, (see drawing)

I.Gil for P. Picazo Surveyors to Lloyd's Register

DOCUMENTS ATTACHED: 12 sheets reviewed and stamped accordingly

DAD POS: TITY ITEM	MEANORESON 3/3/95
PESO KGJ ROAD WEGGHT QUANTITY IS 4	HYE x 25 AC200ABS50N 31/3 ESF14F14 100 30 / 30 / 30 / 30 / 30 / 30 / 30 /
DN REDUCTOR P WORM GEAR 8" AB SSON	DIN 912 8.8 ZINC PLATED CARBON ST ALECTO PLASTIC STANLESS ST. GRAPHITE VITON A 10S CARBON ST. A 25% G.F PITE A 10S A 20S & 10S
STER OF STER O	91.1.7 4.1.4 BOLT 94. 1 COUPLING 93
Z08	12 - 17 - 12 - 13 - 13 - 13 - 13 - 13 - 13 - 13



FLANGED BALL VALVE

CHARLES DE VALVULAS, S.A.

BCL 9800603/4 Certificate Number:

BARCELONA

Client's Order Number

30.06.98 Date

Order Status Complete

Inspection Dates

First. 09.06.98

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 2" full bore, bi-directional as per

Fig. 2560 A.I.T. DN 2", ANSI 600# RF,FB

Body material: A-216- WCB

Seats: PTFE

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: 2560501

Body connector: 2560502

Mass: 20,5 Kgs

Marks:

BODY .

ABV

BODY CONNECTOR

ABO

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593° C minimum and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.



Certificate Number. BCL 9800603/4

Office BARCELONA

Date: 30.06.98
Page: 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2560/2"

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.

The manufacturers Fire Safe Test Report no. API 607-2560/2" and drawing 1302/2560NAIT50-M1 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

NPS

CLASS RATING

MATERIALS

11/2", 2", 3", 21/2"


600#, 800 and 900#

Carbon steel, (see drawing)

J.Gil for F. Picazo

Surveyors to Lloyd's Register

DOCUMENTS ATTACHED:





FLANGED BALL VALVE

Certificate Number: BCL 9800547/2

Client: J.C. FABRICA DE VALVULAS, S.A.

Office: BARCELONA

Client's Order Number: ----

Date: 11.05.98

Order Status: complete

Inspection Dates

First. 14.04.98

Final: 14.04.98

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 4" full bore, bi-directional as per

Fig. 2560 A.I.T. 4" ANSI 600# RF; FB SERIE STF

Body material: A-216- WCB

Seats: Ring: PTFE (Trunnion bearing: AISI 316)

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: C2560100.1

Body connector: 2560100.2

Mass: 77 Kgs

Marks:

BODY

BCC3

BODY CONNECTOR

FM

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593°C minimun and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.

../..



Certificate Number: BCL 9800547/2

Office: BARCELONA
Date: 11.05.98
Page: 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2560/4"

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.

The manufacturers Fire Safe Test Report no. API 607-2560/4" and drawing 2210/2560AIT100L herewith attached were satisfactory checked and signed.


The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

<u>NPS</u>	<u>CLASS RATING</u>	MATERIALS
3, 4, 5, 6	600,800,900#	Carbon steel (See drawing)

J.Gil for P. Picazo

Surveyers to Lloyd's Register

DOCUMENTS ATTACHED:





FLANGED BALL VALVE

Client: J.C. FABRICA DE VALVULAS, S.A.

Certificate Number: BCL 9800786/1

Office: BARCELONA

Client's Order Number: -----

Date: 25.01.99

Order Status: Complete

Inspection Dates

First: 29.12.98

Final: 22.01.99

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS, S.A. upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607-1993 on the following type of valve:

A manually operated soft seated flanged ball valve of 8" reduced bore, bi-directional as per

Fig. 2560 A.I.T. DN 8", ANSI 600# RF,FB

Body material: A-216- WCB

Seats: PTFE

Ball material: A-351 CF8M

Manufacturers identifying numbers: BODY: 715841

Body connector: A-216- WCB Drawing: 2697/2560HAIT200RA

Marks:

BODY

Y05

BODY CONNECTOR

Y34

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve, filled with water under test pressure, was put in a box and exposed to flames with and environmental temperature between 760 - 980°C. All measure temperatures shall be above 705°C. The body temperature shall be at 593° C minimun and bonnet temperature of 650°C minimum for a period of during 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every each thirty seconds, while leakages were determined using containers collecting the water leaked during burn period. Afterwards water spray so that it is rapidly cooled to below 100°C within ten minutes. Internal leakage measure during cooling time. Following operational test. Subsequently manual opened up and closed to under test pressure differential and finally the valve was hidrotested during five minutes and during this period internal and external leakage were measured.

../..

NOTICE: This certificate is subject to the terms and conditions overleaf, which form part of this certificate.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no. API 607-2560/8".

- 1.-Internal leakage during burning test Satisfactory
- 2.-External leakage during burning and cooling test Satisfactory
- 3.-Operatibility to full open position test Satisfactory
- 4.-Internal and External leakage during after operational test Satisfactory

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found partially destroyed.

The manufacturers Fire Safe Test Report no. API 607-2560/8" and drawing no. 2697/2560HAIT200 RA herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

N T	\sim
NI.	_

CLASS RATING

MATERIALS

6" and larger

600# - 800# - and 900#

Carbon steel, (see drawing)

J.Gil Surveyor to Lloyd's Register

DOCUMENTS ATTACHED:

14 sheets reviewed and stamped accordingly

NOTICE: This certificate is subject to the terms and conditions overleaf, which form part of this certificate.

FORM 1123 (05/96)

Lloyd's Register of Shipping, registered office: 71 Fenchurch Street, London EC3M 4BS

	di Carantana di Ca	DETRICTOR	CANTIDAD
		8	QUANTITY ITEM
655 235 · · · 48 · · · 500 · · · 104.5 · 3		8 AB 1250N	
1	- T		
	B WORLD 199:		(
	The second second		BOILD AND FOUND WERE ST.
B MEM	>		9-1 9-8007-86/1
さんしょう 一般はそれである こう			۱ -
VICH V NCH V	ļ		M6X25
	•	DIN 912 0.0	MAKYS
	912.1 4 BOLT	UIN 912 8.8 STAINI FSS ST	DIN 471 (50X2)
	94 1 CXIPING	CARBON ST.	11-111
	93 1 MOUNTING BRACKET	SI.	ESF14F14120 21/11/97
	-	ALECTO	. AB1250N
	2 WOOD DISK	000M	440
	89 1 IDENTIFICATION PLATE	STAINLESS SI.	644.043.53
	-	CARBON ST. FMRE3001	
_	54 2 SEAT SEAL	<u> </u>	53
/	-	WTON .	3./8 NDT
	50.1 1 DRAIN PLUG	A- 105	1/2 NPT
	- "	31 316	IN 6885 B14X
	,	AIS 316 5384/43	/43 23/07/85
	2		\$210X3
	2 SEAT	1 GR. CF8M	SAPR2002515 16/02/98
	2 SEAT		#228.19X3.53
	₽	- 750	MRA130363 13/01/93
	2 SEAT	C COM	N2620450 29/09/94
	9	A 194 Gr. ZHM	WRX25
	+	DIE SIZ 0.0	#15Xe95X1
	23 Z DEARING STARING	ASI316 WITH INSDE PITE	\$100X\$95X19
	11/11	GR. CFBM	GBM2002560 25/03/97
	2 ANTI	SS ST.	
	9		52630450 03/01/96
(35)	2 STOP	7.	10X/0 DN 6325
	-	316L + GRAPHITE	3G-2003F36U 01/03/34
4	- .	25% G.F. PIFE	ø60Xø50X5.4
	10 5 GLAND PACKING	15	WPP3001516 29/11/94
dø	10 1 GAND		Н
3	-	BON ST.	02515-M1
	Н	ST.	29/11/94
	2		AD2560200 18/02/98
		A 2/6 / 4/9 Ip.316 E230	
	3 1 BALL		+
	1	A 216 Gr. WCB (C ≤ 0.25%) C256	C2560A200-M1 02/98
	į	3	N'DE PLANO FECHA
		CONVINCE	
	Dibujodo	L. F. COMPANIEL	Fabrica de valvulas, s.a.
	Comprehensiones 28.1.99	- CA	Hosnitalet de 11 (Barcelond)
_	Peso (Kg) 360 V.B.Ing.	Papadeol.	(Carcara)
	1 7	C ® DAIL VALVE	Ref.
	 	JU - DALL VALVE	<u>. </u>
	FIG.	8 N	Plano n.
	Sustituye a	WORM GEAR ALECTO	2697 / 2560HAIT200RA



This Certificate cancels and superseded the previous one BCL 9700816/1 issued on 20.01.98

Project: FIRE TEST FOR SOFT-SEATED

FLANGED BALL VALVE

Certificate Number: BCL 9700816/1A1

Client: J.C.FABRICA DE VALVULAS, S.A.

Office: BARCELONA

Client's Order Number: ----

Date: 05.03.98

Order Status: complete

Inspection Dates

First: 29.12.97

Final: 08.01.98

This certificate is issued to Messrs. J.C.FABRICA DE VALVULAS, S.A., upon their request that the undersigned Surveyor to this Society did attend their works at Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1897, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operated soft seated flanged ball valve of 14" full bore, bi-directional as per

fig. 2515AIT 14", class 150#. Body material: A-216-WCB. Seats: ENP Carbon St. + PTFE Ball material: A-351-CF8M

Manufacturers identifying numbers: BODY: C2515A3501

Body connector: L2515A3501 and Ball: B615337

Mass: 604 Kg.

Marks:

BODY : 918

BODY CONNECTOR: 959

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve leakage hydrostatically tested to the appropriate test pressure and external leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and external leakages recorded.

../..



Certificate Number: BCL 9700816/1A1

Office: BARCELONA Date: 05.03.98

Page: 2 of 2

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no 2515-14A and 2515-14B.

- 1. External leakage during burn and cool-down period satisfactory.
- 2. External leakage during operational test satisfactory.
- 3. Operatibility to full open position and external leakage satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report no 2515.14A and 2515-14B and drawing 2039/2515AIT350RA herewith attached were satisfactory checked and signed.


The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactorily passed the prescribed fire test and can be also qualified as follows:

<u>NPS</u>	CLASS RATING	<u>PN RATING</u>
14", 16", 18", 20", 24" & 28"	150 and 300	16, 25 and 40



Surveyors to Lloyd's Register

DOCUMENTS ATTACHED:





Sheet 1 of 2

FIRE TEST FOR SOFT-SEATED Project:

FLANGED BALL VALVE

Certificate No.:

BCL 500929/7

J.C.FABRICA DE VALVULAS S.A.

Office:

BARCELONA

Client's Order No.:

Date:

07.06.96

Order Status:

Complete

Inspection dates 03.05.96

First:

03.05.96 Final-

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS S.A., upon their request that the undersigned Surveyor to this Society did attend their premises at their works in Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1987, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operated soft seated flanged ball valve of 6" full bore, bi-directional as per fig.2560 AIT, class 600 #. Body material A-216-WCB.

Seats: PTFE.

Ball material: A-531-CF8M.

Manufacturers identifying numbers: BODY: C2560A150SI.

Bonnet: L2560A150SI and Ball: B2515150.

Mass: 192.5 Kg.

Marks:

685 BODY BONNET 685

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report nº 2560-6A & 2560-6B.





Certificate Nº: BCL 500929/7

Office

:Barcelona

Date

:07.06.96

Sheet 2 of 2

1. Through-valve leakage during burn period-Satisfactory.

External leakage during burn and cool-down period-Satisfactory.

3. Through-valve leakage during operational test-Satisfactory.

4. External leakage during operational test-Satisfactory.

5. Operatibility to full open position and external leakage-Satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list suplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report nº 2560-6A, 2560-6B and drawing nº 1359/2560AIT150 FLSI Rev. 0 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows:

NPS	CLASS RATING	<u>PN RATING</u>
60 80 100 £ 120	600 800 & 900	

May


BARCELONA RECISTER OF SHIPP

J. Gil for N. Cano Surveyors to Lloyd's Register

DOCUMENTS ATTACHED: 17 Sheets reviewed and stamped accordingly.



FOR





Sheet 1 of 2

FIRE TEST FOR SOFT-SEATED

FLANGED BALL VALVE

Certificate No.:

BCL 500929/6

J.C.FABRICA DE VALVULAS S.A.

Office:

BARCELONA

Client's Order No.:

Date:

07.06.96

Order Status:

Complete

Inspection dates 19.04.96

19.04.96 Final:

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS S.A., upon their request that the undersigned Surveyor to this Society did attend their premises at their works in Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1987, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operated soft seated flanged ball valve of 6" full bore, bi-directional as per fig.2515 AIT, class 150 #.

Body material A-216-WCB.

Seats: PTFE.

Ball material: A-351-CF8M.

Manufacturers identifying numbers: BODY: C2515A150SI.

Bonnet: L2515A150SI and Ball: B2515150.

Mass: 95 Kg.

Marks:

BODY

1164.1

BONNET

1171.1/ABC

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report nº 2515-6A & 2515-6B.



Certificate Nº: BCL 500929/6

Office

:Barcelona

Date

:07.06.96

Sheet 2 of 2

Through-valve leakage during burn period-Satisfactory.

 External leakage during burn and cool-down period-Satisfactory.

3. Through-valve leakage during operational test-Satisfactory.

4. External leakage during operational test-Satisfactory.

5. Operatibility to full open position and external leakage-Satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list suplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report nº 2515-6A, 2515-6B and drawing nº 1360/2515AIT150 FSI Rev. 0 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows:


NPS	CLASS RATING	PN RATING
6", 8", 10" & 12"	150 & 300	

FOR STATE OF THE S



J. Gil for N. Cano Surveyors to Lloyd's Register

DOCUMENTS ATTACHED: 17 Sheets reviewed and stamped accordingly.





Sheet 1 of 2

Project: FIRE TEST FOR SOFT-SEATED

FLANGED BALL VALVE

Certificate No .:

BCL 500929/5

Client: J.C.FABRICA DE VALVULAS S.A.

Office:

BARCELONA

Client's Order No.:

Date:

21.03.96

Order Status:

Complete

Inspection dates First: 07.03.96

Final:

07.03.96

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS S.A., upon their request that the undersigned Surveyor to this Society did attend their premises at their works in Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1987, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operated soft seated flanged ball valve of 2" full bore, bi-directional as per fig.2560 AIT, class 600#.

Body material A-216-WCB (cast steel).

Seats: PTFE.

Ball material: A-351CF8M.

Manufacturers identifying numbers: BODY: C2560A50SI.

Bonnet: L2560A50-M2 and Ball: B251550-M1.

Mass: 20,5 Kg.

Marks:

BODY

ABV

BONNET

ABO

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report nº 2560-2A & 2560-2B.



Certificate Nº: BCL 500929/5

Office

:Barcelona

Date

:21.03.96

Sheet 2 of 2

1. Through-valve leakage during burn period-Satisfactory.

External leakage during burn and cool-down period-Satisfactory.

3. Through-valve leakage during operational test-Satisfactory.

4. External leakage during operational test-Satisfactory.


5. Operatibility to full open position and external leakage-Satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list suplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report n° 2560-2A, 2560-2B and drawing n° 1302/2560NAIT50 Rev. 0 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows:


NPS	<u>CLASS RATING</u>	PN RATING
2", 25", 3" & 4"	600, 800 & 900	



J. Gil for N. Cano Surveyors to Lloyd's Register

DOCUMENTS ATTACHED: 17 Sheets reviewed and stamped accordingly.







RECIBION 09 /27. 1998

Cart.

Sheet 1 of 2

FIRE TEST FOR SOFT-SEATED

FLANGED BALL VALVE

Certificate No .:

BCL 500929/4

Client: J.C.FABRICA DE VALVULAS S.A.

BARCELONA Office:

Client's Order No.:

Date:

21.03.96

Order Status:

Complete

Inspection dates First: 02.02.96

Final-

02.02.96

This certificate is issued to Messrs. J.C. FABRICA DE VALVULAS S.A., upon their request that the undersigned Surveyor to this Society did attend their premises at their works in Rubi - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1987, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operated soft seated flanged ball valve of 2" full bore, bi-directional as per fig.2515AIT, class 150#.

Body material A-216-WCB (cast steel).

Seats: PTFE.

Ball material: A-351CF8M.

Manufacturers identifying numbers: BODY: C2515A50SI.

Bonnet: L2515A50-M2 and Ball: B251550-M1.

Mass: 13 Kg.

Marks:

BODY

994HI

BONNET

994HI

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage through the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report nº 2515-2A & 2515-2B.





Certificate Nº: BCL 500929/4

Office

:Barcelona

Date

:21.03.96

Sheet 2 of 2

1. Through-valve leakage during burn period-Satisfactory.

2. External leakage during burn and cool-down period-Satisfactory.

3. Through-valve leakage during operational test-Satisfactory.

4. External leakage during operational test-Satisfactory.

5. Operatibility to full open position and external leakage-Satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list suplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report nº 2515-2A, 2515-2B and drawing nº 1303/2515NAIT50 Rev. 0 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows:

NPS	CLASS RATING	PN RATING
2", 2½", 3" & 4"	150 & 300	16, 25 & 40



J. Gil for N. Cano Surveyors to Lloyd's Register

DOCUMENTS ATTACHED: 17 Sheets reviewed and stamped accordingly.



