

Las Planas, nº. 1, - Nave B Pol. Ind. FONTSANTA 08970 - SANT JOAN DESPÍ

(Barcelona) - España Tel.: +34+934770171 - 934770169

Fax: +34+933731500

Sheet 1 of 2

Project: FIRE TEST FOR SOFT-SEATED

BALL VALVE

Certificate No.: 102/02

Client: J.C. FÁBRICA DE VÁLVULAS, S.A.

Office: Sant Joan Despí (BCN)

Client's Order No.::

Date: 18.04.02

Order Status: Complete

Inspection dates

First: 08.03.02

Final: 08.03.02

This certificate is issued to

Messrs. J.C. FABRICA DE VÁLVULAS, S.A., upon their request that the undersigned Suveryor to this Society did attend their premises at their works in Sant Boi de Llobregat -Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in BS-6755: Part 2, 1987, API 6FA: 1994, and ISO-10497/92 on the following type of valve:

A manually operate, soft seated, BW ball valve of 6" bore 4", symetric valve as per fig. 7260 AIN.

Body and Connector material A-105 (Carbon Steel)

Seats: NYLON

Ball material: A-351 Gr CF8M

Stem: AISI 316

Marks:

: Col. 6649 - BODY - CONNECTOR: Col. 227323

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage trough the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cooldown to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no 7260 - 6"



Ins. Reg. Merc. Madrid Tomo 3.475, Gral. 2.746, Secc. 3.º Libro de Sociedades, Folio 88, Hoja 25.966, Inscripción 1.º N.I.F. A-28345577



Certificate No.: 102/02

Office: Sant Joan Despí (BCN)

Date: 18.04.02 Sheet 2 of 2

- 1. Through-valve leakage during burn period-Satisfactory.
- 2. External leakage during burn and cool-down period-Satisfactory.
- 3. Through-valve leakage during operational test-Satisfactory.
- 4. External leakage during operational test-Satisfactory.
- 5. Operatibility to full open position and external leakage-Satisfactory.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while scat rings were found completely destroyed.

The manufacturers Fire Safe Test Report no 7260 - 6" and drawing no 4056 Rev. 0 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows:

_	NPS	CLASS RATING	PN RATING
	Full Bore: 4", 5", 6" and 8"	300# - 400# - 600#	25 and 40
]	Reduced Bore: 6", 8", 10" and 12"	300# - 400# - 600#	25 and 40

Superveyor

Pol. Ind. Facing 19 08970 SART SART DESP( (BARCGLOWA) I SPARA Tol.: +84 +894770771 - 9947 Fax.: +84 + coare+cat

Salvador Valo

DOCUMENTS ATTACHED:

GRAND SGS Tacnos, S.A. Las Morto of 1 - Nove B

Sheets reviewed and stamped Accordingly.

