



TEST ACCORDING TO

MESC SPE 77/312 ed.2004 - STAR FE101-PROTOTYPE – ISO 14001 –
ASME SEZ. V Article 10, Appendix IV Last Edition – ASME B16.34 & Addenda Last Edition

EQUIPMENTS

Mass Spectrometer manufactured by : LEYBOLD AG model : PHOENIX L300

Serial n° : 90001041842

Range: 1×10^{-8} (sniffing)
 5×10^{-12} (vacuum)

Calibrated Leak manufactured by : ESA s.r.l. model : PTL60 range 10^{-6}

Serial n° : 020805-059

Mass Spectrometer Calibrated Before Testing

VALVES DESCRIPTION	SIZE	CLASS	QUALIFIED VALVES		TEST REPORT AT PAGE
				CLASS	
ULTRASTAR	3/4" x 3/4" 1"x3/4"	300	1/2"x1/2" - 3/4"x1/2" - 1"x1"-1.1/4"x1" - 1.1/4x1.1/4" - 1.1/2"x1"	150 - 300	2
	2"x2" 2.1/2"x2"	300	1.1/2"x1.1/2" - 2"x1.1/2" - 2.1/2"x2.1/2" - 3"x2" - 3"x3" - 4"x3"	150 - 300	2
	4"x4" 6"x4"	300	3"x3" - 4"x3" - 6"x6" - 8"x6" - 8"x8" - 10"x8"	150 - 300	2
	3/4" x 3/4" 1"x3/4"	900	1/2"x1/2" - 3/4"x1/2" - 1"x1"-1.1/4"x1" - 1.1/4x1.1/4" - 1.1/2"x1"	600 - 900	3
	2"x2" 2.1/2"x2"	900	1.1/2"x1.1/2" - 2"x1.1/2" - 2.1/2"x2.1/2" - 3"x2" - 3"x3" - 4"x3"	600 - 900	3
	4"x4" 6"x4"	900	3"x3" - 4"x3" - 6"x6" - 8"x6" - 8"x8" - 10"x8"	600 - 900	3
	3/4" x 3/4" 1"x3/4"	2500	1/2"x1/2" - 3/4"x1/2" - 1"x1"-1.1/4"x1" - 1.1/4x1.1/4" - 1.1/2"x1"	1500 - 2500	4
	2"x2" 2.1/2"x2"	2500	1.1/2"x1.1/2" - 2"x1.1/2" - 2.1/2"x2.1/2" - 3"x2" - 3"x3" - 4"x3"	1500 - 2500	4
	4"x4" 6"x4"	2500	3"x3" - 4"x3" - 6"x6" - 8"x6" - 8"x8" - 10"x8"	1500 - 2500	4

Notes:

OPERATOR QUALIFIED IN ACCORDANCE
UNI EN473 - LEVEL 1

Jeremy Gritti



INSPECTOR



WITNESSEI)

[Handwritten signature]
06-01-06

Date: 26-01-2006

VALVE DESCRIPTION AND TESTS REPORTS

TYPE:	ULTRASTAR
PRESSURE CLASS:	300
TEMPERATURE CLASS:	T6
ENDURANCE CLASS:	CO-QT-SS-ML

Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 34 cycles at ambient temperature	Max leakage After 34 cycles at -46°C	Max leakage After 34 cycles at +80°C
3/4"x3/4" 1"x3/4"	stem	16.2	2.8x10 ⁻⁵	20	8x10 ⁻⁷	6x10 ⁻⁷	9x10 ⁻⁷	5x10 ⁻⁷
	Body/ Ends	43	2.4x10 ⁻⁵		9x10 ⁻⁷	9x10 ⁻⁷	1x10 ⁻⁶	6x10 ⁻⁷
2"x2" 2.1/2"x2"	stem	25.2	4.4x10 ⁻⁵	20	2x10 ⁻⁷	2x10 ⁻⁷	8x10 ⁻⁷	6x10 ⁻⁷
	Body/ Ends	92	5.1x10 ⁻⁵		8x10 ⁻⁷	6x10 ⁻⁷	6x10 ⁻⁷	6x10 ⁻⁷
4"x4" 6"x4"	stem	40.2	7.0x10 ⁻⁵	20	2x10 ⁻⁶	1x10 ⁻⁶	2x10 ⁻⁶	1x10 ⁻⁷
	Body/ Ends	182	1.0x10 ⁻⁴		3x10 ⁻⁶	4x10 ⁻⁶	6x10 ⁻⁶	4x10 ⁻⁶

TYPE:	ULTRASTAR
PRESSURE CLASS:	300
TEMPERATURE CLASS:	T7
ENDURANCE CLASS:	CO-QT-SS-ML

Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 50 cycles at ambient temperature	Max leakage After 50 cycles at +150°C
3/4"x3/4" 1"x3/4"	stem	16.2	2.8x10 ⁻⁵	20	1x10 ⁻⁶	8x10 ⁻⁷	3x10 ⁻⁷
	Body/ Ends	43	2.4x10 ⁻⁵		4x10 ⁻⁷	2x10 ⁻⁷	2x10 ⁻⁷
2"x2" 2.1/2"x2"	stem	25.2	4.4x10 ⁻⁵	20	9x10 ⁻⁷	1x10 ⁻⁶	2x10 ⁻⁶
	Body/ Ends	92	5.1x10 ⁻⁵		4x10 ⁻⁶	2x10 ⁻⁶	2x10 ⁻⁶
4"x4" 6"x4"	stem	40.2	7.0x10 ⁻⁵	20	1x10 ⁻⁶	8x10 ⁻⁷	8x10 ⁻⁷
	Body/ Ends	182	1.0x10 ⁻⁴		4x10 ⁻⁶	3x10 ⁻⁶	3x10 ⁻⁶

Notes:

OPERATOR QUALIFIED IN ACCORDING TO
 UNI EN473 - LEVEL II

Jeremy Grilli



INSPECTOR



AIT NEBSEI

[Signature]
 25/01/06

Date: 25-01-2006

VALVE DESCRIPTION AND TESTS REPORTS

TYPE:		ULTRASTAR						
PRESSURE CLASS:		900						
TEMPERATURE CLASS:		T6						
ENDURANCE CLASS:		CO-QT-SS-ML						
Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 34 cycles at ambient temperature	Max leakage After 34 cycles at -46°C	Max leakage After 34 cycles at +80°C
3/4"x3/4" 1"x3/4"	stem	16.2	2.8x10 ⁻⁵	30	3x10 ⁻⁷	2x10 ⁻⁷	6x10 ⁻⁷	6x10 ⁻⁷
	Body/ Ends	43	2.4x10 ⁻⁵		8x10 ⁻⁷	8x10 ⁻⁷	8x10 ⁻⁷	8x10 ⁻⁷
2"x2" 2.1/2"x2"	stem	28.2	4.9x10 ⁻⁵	30	6x10 ⁻⁷	4x10 ⁻⁷	8x10 ⁻⁷	6x10 ⁻⁷
	Body/ Ends	92	5.1x10 ⁻⁵		3x10 ⁻⁶	3x10 ⁻⁶	4x10 ⁻⁶	2x10 ⁻⁶
4"x4" 6"x4"	stem	55.2	9.7x10 ⁻⁵	30	2x10 ⁻⁶	1x10 ⁻⁶	5x10 ⁻⁶	1x10 ⁻⁶
	Body/ Ends	182	1.0x10 ⁻⁴		3x10 ⁻⁶	3x10 ⁻⁶	6x10 ⁻⁶	2x10 ⁻⁶

TYPE:		ULTRASTAR					
PRESSURE CLASS:		900					
TEMPERATURE CLASS:		T7					
ENDURANCE CLASS:		CO-QT-SS-ML					
Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 50 cycles at ambient temperature	Max leakage After 50 cycles at +150°C
3/4"x3/4" 1"x3/4"	stem			30	6x10 ⁻⁷	1x10 ⁻⁷	1x10 ⁻⁷
	Body/ Ends				2x10 ⁻⁷	2x10 ⁻⁷	1x10 ⁻⁷
2"x2" 2.1/2"x2"	stem			30	6x10 ⁻⁷	1x10 ⁻⁷	2x10 ⁻⁷
	Body/ Ends				4x10 ⁻⁷	9x10 ⁻⁷	2x10 ⁻⁷
4"x4" 6"x4"	stem			30	8x10 ⁻⁷	8x10 ⁻⁷	8x10 ⁻⁷
	Body/ Ends				4x10 ⁻⁶	2x10 ⁻⁶	2x10 ⁻⁶


Notes:

OPERATOR QUALIFIED IN ACCORDING TO
 UNI EN473 - LEVEL II

Jeremy Gritti



INSPECTOR



WITNESSED

26-01-2006

Date: 26-01-2006

VALVE DESCRIPTION AND TESTS REPORTS

TYPE:		ULTRASTAR						
PRESSURE CLASS:		2500						
TEMPERATURE CLASS:		T6						
ENDURANCE CLASS:		CO-QT-SS-ML						
Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 34 cycles at ambient temperature	Max leakage After 34 cycles at -46°C	Max leakage After 34 cycles at +80°C
3/4"x3/4" 1"x3/4"	stem	16.2	2.8x10 ⁻⁵	84	8x10 ⁻⁶	3x10 ⁻⁶	6x10 ⁻⁶	4x10 ⁻⁶
	Body/ Ends	43	2.4x10 ⁻⁵		2x10 ⁻⁶	2x10 ⁻⁶	5x10 ⁻⁶	3x10 ⁻⁶
2"x2" 2.1/2"x2"	stem	28.2	4.9x10 ⁻⁵	84	7x10 ⁻⁶	2x10 ⁻⁷	8x10 ⁻⁷	6x10 ⁻⁷
	Body/ Ends	92	5.1x10 ⁻⁵		8x10 ⁻⁶	6x10 ⁻⁶	8x10 ⁻⁶	6x10 ⁻⁷
4"x4" 6"x4"	stem	90	1.6x10 ⁻⁴	84	9x10 ⁻⁶	6x10 ⁻⁶	8x10 ⁻⁶	3x10 ⁻⁶
	Body/ Ends	186	1.0x10 ⁻⁴		1x10 ⁻⁵	4x10 ⁻⁶	7x10 ⁻⁶	5x10 ⁻⁶

TYPE:		ULTRASTAR						
PRESSURE CLASS:		2500						
TEMPERATURE CLASS:		T7						
ENDURANCE CLASS:		CO-QT-SS-ML						
Valve Size	Test	Tightness size	Max allowable leakage	Test Pressure (Bar)	Max leakage at ambient temperature	Max leakage After 50 cycles at ambient temperature	Max leakage After 50 cycles at +150°C	
3/4"x3/4" 1"x3/4"	stem	16.2	2.8x10 ⁻⁵	84	1x10 ⁻⁶	9x10 ⁻⁷	1x10 ⁻⁶	
	Body/ Ends	43	2.4x10 ⁻⁵		8x10 ⁻⁷	6x10 ⁻⁷	7x10 ⁻⁷	
2"x2" 2.1/2"x2"	stem	28.2	4.9x10 ⁻⁵	84	3x10 ⁻⁶	2x10 ⁻⁶	5x10 ⁻⁷	
	Body/ Ends	92	5.1x10 ⁻⁵		8x10 ⁻⁶	8x10 ⁻⁷	8x10 ⁻⁷	
4"x4" 6"x4"	stem	90	1.6x10 ⁻⁴	84	5x10 ⁻⁵	1x10 ⁻⁵	8x10 ⁻⁶	
	Body/ Ends	186	1.0x10 ⁻⁴		5x10 ⁻⁵	8x10 ⁻⁶	3x10 ⁻⁶	

Notes:

OPERATOR QUALIFIED IN ACCORDING TO
 UNI EN473 - LEVEL II

Jeremy Gritti



INSPECTOR

[Handwritten Signature]
 26/01/06
 WITNESSEI

Date: 26 - 01 - 2006