



ATTESTATION OF CONFORMITY

No. 03I1562.01

Issued to: Biffi Italia S.r.l.
Via Caselle San Pietro, 420
29017 Fiorenzuola D'arda (PC) - Italy

For the product: Pneumatic and Hydraulic Actuator

Trademark Biffi Italia S.r.l.

Series ALGA/ALGAS; OLGA/OLGAS; OLGA-H/OLGAS-H; GIG/GIGS and
GPO(OGK)/GPOS.
Note: for the complete list of the models refers to the attachment of the
report No.: 03I1562.50

Manufactured by: Biffi Italia S.r.l.
Via Caselle San Pietro, 420
29017 Fiorenzuola D'arda (PC) - Italy

Tested according: EN 60529:91 + A1:00
NEMA 250: 2003

Results: Sample were tested and found to be in conformity with the requirements
for Protection Degree IP 67M acc to EN 60529 and NEMA 4,4X and 6
according to NEMA 250.

This Attestation refers to the tests made at KEMA Quality Italia S.r.l. The detailed results of the tests are laid down in our report: No. 03I1562.50 and 11482.51

The tests have been carried out on a representative sample submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of the production with the specimen tested by KEMA is not the responsibility of KEMA.

This KEMA Quality Attestation of Conformity replaces previous one dated January 16, 2004 and covers the NEMA degrees 4, 4X and 6.

KEMA Quality Italia S.r.l.
Osnago (LC), November 12, 2007

Walter Parmiani
Test Engineer

Davide Atzeni
Project Leader

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality Italia S.r.l.

Via Martiri della Liberazione,12 23875 Osnago (LC),Italy.
Telephone +39 039 9280177, Telefax +39 039 9280294.