

**Certificate no. TAI-FS-C-21-0095**

WE HEREBY CERTIFY THAT

**Product description** PNEUMATIC RACK AND PINION SPRING RETURN AND DOUBLE ACTING ACTUATOR

**Models** SERIES RPS, RPS-C, RPD, RPD-C

**Manufacturer** BIFFI ITALIA S.r.l.  
Strada Biffi 165  
I-29017 Fiorenzuola d'Arda (PC)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

**IEC 61508 Parts 1–7:2010**

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

**Summary Report no. TAI-FS-R-21-0191**

**Expiry date 05.10.2024**

**Issue date 06.10.2021**

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
06.10.2021, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

**TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.**  
Sede operativa: Via dell'Industria, 14 – 25030 Erbusco - Brescia, Italy  
Phone +39 030 9821049 Fax +39 030 9822253 [info.bs@tuvaustralia.com](mailto:info.bs@tuvaustralia.com)  
Sede legale: Via del Commercio, 6/A - 60030 Monte Roberto - Ancona, Italy  
Cap. Soc. i.v. EUR 10.000,00; R.I. Ancona – C.F. – P. IVA 02217380423  
Cod. Id. CEE IT02217380423 REA AN n. 170070  
A socio unico, soggetta a controllo e coordinamento di:  
TÜV AUSTRIA HOLDING AG, Deutschstrasse 10, 1230, Vienna, Austria  
[www.tuvaustriaitalia.com](http://www.tuvaustriaitalia.com) [www.tuv.at](http://www.tuv.at)

## Annex to certificate no. TAI-FS-C-21-0095

<b>Type</b>	A
<b>HFT</b>	0
<b>Safety functions</b>	<u>Spring return actuators:</u> 1. Delivery of a full stroke ( $90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ( $90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
<b>Mode of operation</b>	Low Demand Mode


Random failure rates				
Configuration	Safety function	$\lambda_{DU}$ [1/h]	$\lambda_{DD}$ [1/h]	$\lambda_S$ [1/h]
RPS, RPS-C - No PST	1	1,46E-08	0,00E+00	0,00E+00
RPS, RPS-C - With PST	1	1,31E-09	1,33E-08	0,00E+00
RPD, RPD-C - No PST	1	1,99E-08	0,00E+00	0,00E+00
RPD, RPD-C - With PST	1	1,80E-09	1,82E-08	0,00E+00

<b>Systematic capability</b>	3 (Route 1s applied)			
<b>Architectural constraints</b>	<b>Route 1<sub>H</sub>:</b>	Applied	<b>Route 2<sub>H</sub>:</b>	Applied
	The product can be used in: <ul style="list-style-type: none"> <li>• single channel configuration:                             <ul style="list-style-type: none"> <li>○ up to SIL 2 without external diagnostic tests</li> <li>○ up to SIL 3 considering external diagnostic tests</li> </ul> </li> <li>• double channel configuration: up to SIL 3</li> </ul>			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manuals SM 023, SM 002.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
06.10.2021, Monte Roberto (AN)



Ing. Crescenzo Di Fratta